



中国国家强制性产品认证证书



证书编号: 2020322307000465

认证委托人名称: Eugen Seitz AG
 认证委托人地址: Spitalstrasse 204, 8623 Wetzikon, Switzerland
 生产者名称: Eugen Seitz AG
 生产者地址: Spitalstrasse 204, 8623 Wetzikon, Switzerland
 生产企业名称: Magnet-Schultz GmbH & Co. KG
 生产企业地址: Allgäuer Strasse 30, 87700 Memmingen, Germany
 产品名称: 电磁线圈
 系列、规格、型号: 2F86
 标准: GB/T 3836.1-2021、GB/T 3836.9-2021

认证模式: 型式试验+初始工厂检查+获证后监督

上述产品符合 CNCA-C23-01:2019 《强制性产品认证实施规则 防爆电气》的要求, 特发此证。产品相关信息详见附件。

发证日期: 2023年03月20日

有效期至: 2025年07月22日

首次发证日期: 2020年07月23日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准:



上海仪器仪表自控系统检验测试所有限公司

<http://www.sitias.com.cn>

中国·上海·漕宝路103号200233

电话: +86 21 64510844

S 0008681



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322307000465

APPLICANT: Eugen Seitz AG
ADDRESS: Spitalstrasse 204, 8623 Wetzikon, Switzerland
MANUFACTURER: Eugen Seitz AG
ADDRESS: Spitalstrasse 204, 8623 Wetzikon, Switzerland
FACTORY: Magnet-Schultz GmbH & Co. KG
ADDRESS: Allgäuer Strasse 30, 87700 Memmingen, Germany

PRODUCT: Solenoid Coil
SERIES,SPECIFICATION,MODEL: 2F86
STANDARDS: GB/T 3836.1-2021、GB/T 3836.9-2021

Type of Certification: Type test + Initial inspection + Surveillance inspection
 This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019). Refer to the attachment for detailed information.

Valid from:March 20, 2023 **Valid until:**July 22, 2025

Date of original certification:July 23, 2020

The validity of this certificate is subject to positive result of the periodic surveillance by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL: 
 Guo AiHua



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitiias.com.cn>

Building 9, 103 Cao Bao Road, Shanghai 200233, China

Tel: +86 21 64510844

S 0007003



中国国家强制性产品认证证书



证书编号：2020322307000465

附 件

- 产品名称：** 电磁线圈
- 型号规格：** 2F86
Art. No. 275.275.XXXB
XXX表示额定电压，代码为024~230。
- 防爆标志：** Ex mb IIC 150°C (T3)...T4 Gb
- 电气参数：** 额定电压：24V AC/DC ±15%、230V AC±15% 额定功率：16W
- 相关报告编号：** 2023S17402-010791、2021S17402-006336
- 使用条件：**
- 特殊（限制）使用条件：
 - 电磁线圈所配阀体必须具有良好的导热性，以保证其最高表面温度符合温度组别的要求。
 - 电磁阀使用时应注意介质温度对电磁线圈的影响，以保证其最高表面温度符合温度组别的要求。
 - 电磁线圈电源回路应配置一个最大额定值为三倍于电磁线圈额定电流的熔断器。熔断器均应具有1500A以上分断能力（符合GB9364或IEC60127标准），且额定工作电压不得小于电磁线圈的工作电压。
 - 使用环境温度与温度组别关系：
150°C (T3)：-50°C~+85°C
T4：-50°C~+65°C

批 准：



上海仪器仪表自控系统检验测试所有限公司